



- NOTES:**
1. PROVIDE DEDICATED QUAD (NOT SHOWN) IN EACH ELECTRIC ROOM FED FROM HOUSE PANELS.
 2. PROVIDE NEW LED SURFACE MOUNTED STRIP LIGHTING (NOT SHOWN) IN EACH NEW ELECTRIC ROOM.
 3. PROVIDE NEW BATTERY POWERED EMERGENCY LIGHT (NOT SHOWN) IN EACH ELECTRIC ROOM.
 4. PROVIDE NEW SMOKE DETECTOR (NOT SHOWN) IN EACH ELECTRIC ROOM.

286-288 Chestnut Hill Avenue

Boston, MA

Commercial Construction Consulting, Inc.
 313 Congress Street
 Boston, MA 02210
 617.330.9390
 617.330.9383 fax
 info@cccoston.com
 Consulting Engineers/Construction Managers



EC
Existing Conditions Surveys Inc.
 398 Columbus Avenue #334
 Boston, MA 02116 USA
 T 617.247.9161
 F 617.249.0746
 E info@existingconditions.com
 www.existingconditions.com

Revision Schedule		
Revision Number	Revision Description	Revision Date

ELECTRICAL BASEMENT PLAN

Date: 06/27/2022
 Scale: 1/4" = 1'-0"
 Drawn By: SB
 Checked By: BW

E3.00

P:\030\0301\286-288 Chestnut Hill Ave Brighton\DESIGN\CONSTRUCTION\Electrical\Basement\POWER PLAN.dwg (E3.00) April 18, 2024 1:02 PM Steve Bahr