



SECTION B-B

NOTES:

1. IF LEDGE IS ENCOUNTERED PRIOR TO MINIMUM 4'-0" EMBEDMENT IN UNDISTURBED SOIL OR COMPACTED FILL, THE FOUNDATION SHALL BE SOCKETED INTO THE LEDGE. THE DISTANCE INTO LEDGE SHALL BE EQUIVALENT TO HALF THE REMAINING EMBEDMENT DEPTH THAT WOULD BE REQUIRED FOR SOIL.
2. IN THE EVENT THE FOUNDATION CONFLICTS WITH AN EXISTING FOUNDATION OR UTILITY, THE POLE SHALL BE RELOCATED, WITH APPROVAL OF THE ENGINEER, TO A POSITION THAT AVOIDS THE UTILITY AND WHERE THE MINIMUM EMBEDMENT DEPTH CAN BE ACHIEVED.



**Public Works Department
Engineering Division**

1 CITY HALL SQUARE, ROOM 710
BOSTON, MA 02201
(617) 635-4968

SPECIAL LIGHT POLE
FOUNDATION (2 OF 2)

DATE OF ISSUE:
DECEMBER 2024

SCALE: N.T.S.

DETAIL NO.

G.304