



NOTES:

1. MINIMUM OPENING SIZE OF THE GRATE SHALL BE 1- $\frac{1}{4}$ ".
2. GRATE SHALL MATCH THE SIZE OF THE RISER, PER CONTRACT DOCUMENTS, AND SHALL BE REMOVABLE FOR MAINTENANCE PURPOSES.
3. GRATE SHALL BE BOLTED DOWN (THEFT PROTECTED).
4. RIM ELEVATIONS SHALL REFER TO THE BASE OF THE GRATE OPENING AND SHALL BE RELATIVE TO THE BOTTOM OF CURB ELEVATION AT THE INLET OR OUTLET (TYP.) .
5. IF THE INFILTRATION / OVERFLOW STRUCTURE IS CONNECTED TO A STRUCTURE WITH A SUMP, A SUMP IS NOT REQUIRED. IF NOT, THE INFILTRATION / OVERFLOW STRUCTURE SHALL HAVE A 3'-0" MINIMUM SUMP (4'-0" PREFERRED).



**Public Works Department
Engineering Division**

1 CITY HALL SQUARE, ROOM 710
BOSTON, MA 02201
(617) 635-4968

BEEHIVE GRATE

DATE OF ISSUE:
DECEMBER 2024

SCALE: N.T.S.

DETAIL NO.

G.410